

Annexure C

Letter No- 397

Date- 19.06.2026

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. _____ Dated: _____
It is certified that an inspection team headed by Bimal Kumar Rajak A.E.
(Name of Officers with designation) from Ara PHED
inspected the R.P.S. Public School
(Name & Address of the school) on 10-6-2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. H.1 dated 13/6/2026
of _____ (PHED Lab) certified that
the R.P.S. Public School (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till one years

Signature with Seal: [Signature]
Name शक्ति प्रमोद ल पदाधिकारी
Designation नगर स्वास्थ्य अवन प्रमुख
Name & Address of the Office / Department engineer

To R.P.S. Public School
(Name & Address of the Institution) Sakhyoj Nagar
Ara

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report


District Name :Rhojpur
Sample Collected By : Jui Self

Division Name: P.H. Division, Ara

Date of Sampling :- 10-06-2026
Date of Testing :- 13-06-2026

S	Block	Panchayat	Village	Location of Source	Ward No.	Parameters															Remarks
						pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As	Total Coli	
1	Ara	-		Water Sample(Boring Water) Of R.P.S Public School Sahyogi Nager ;Bahiro ;Ara	45	7.464	10	514	334	272	48.09	36.93	33.98	224	0.38	NT	NT	NT	<0.001	-ve	Safe
2	Ara	-		Water Sample(R.O) Of R.P.S Public School Sahyogi Nager ;Bahiro ;Ara	45	6.831	0.8	77	50	60	16.032	4.86	15.99	56	0.02	NT	NT	NT	<0.001	-ve	Safe
3	Ara	-		Water Sample(Hand Pump) Of R.P.S Public School Sahyogi Nager ;Bahiro ;Ara	45	7.339	2.9	433	281	240	43.28	32.07	47.97	208	0.36	NT	NT	NT	<0.001	-ve	Safe
						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-	
Permissible Limit in absence of alternative source						NR	5	-	2000	600	200	100	1000	500	NR	NR	400	1.5	NR	-	

*NT = Not Tested, BDL=Below Detection Limit


 13/06/2026
 Research Assistant
 (Chemist)
 P.H. Division, Ara